



NOTE:  
 1. CONTINUING ENGINEERING RESEARCH RESULTS IN STEADY IMPROVEMENTS. THEREFORE, THESE SPECIFICATIONS AND DATA ARE SUBJECT TO CHANGE WITHOUT NOTICE. CONSULT WITH FACTORY FOR CURRENT CERTIFIED DIMENSIONS.

ITEM	PARTS	MATERIAL
1	MOTOR (11kW)	ALL
2	FAN	HOT DWP GALV
3	TOP FRAME	PP
4	DIFFUSION DECK	PVC
5	FILLER	HOT DWP GALV
6	MILD LEVEL STAND	FRP
7	BSIN	HOT DWP GALV
8	TOWER SUPPORT	FRP
9	DISTRIBUTION TRAY	FRP
10	DISTRIBUTION TRAY CAP	FRP
11	FAN GUARD	HOT DWP GALV
12	MOTOR SUPPORT	HOT DWP GALV
13	BELT GUARD	FRP
14	LADDER	HOT DWP GALV
15	SUMP TANK	FRP
16	PANEL	FRP
17	FAN STACK	FRP

ITEM	SPECIFICATION	QTY
DRAIN	ø3" (ABS SOCKET)	1
OVERFLOW	ø3" (ABS SOCKET)	1
MANUAL MAKE-UP	ø1-1/2" (ABS SOCKET)	1
AUTOMATIC MAKE-UP	ø1-1/2" (ABS SOCKET)	1
OUTLET	ø6" (FLANGE)	1
INLET	ø6"	2

APPROVED	KM LIN	05.18.2007	DWG TITLE:	OVERALL DIMENSION
CHECKED	NOJUN	10.19.2007	DWG DETAIL:	FWS-127-11
DRAWN	HIANG	05.18.2007	DWG NO.:	ADWS-127-110-P1
ITEM	ZENG	05.18.2007	SCALE	1:60
BY	DAE		<b>PROTEC COOLING TOWERS, INC.</b>	